



287 N. Maple Grove Boise, ID 83704 800.574.0330 www.smokeguard.com

M3000 ELECTRICAL NOTES:

- M3000 ELECTRICAL NOTES:

 1. CONTROLLER CONDUIT BY OTHERS

 2. CONTROLLER CABLE PROVIDED

 3. MAX 30 CONDUIT FEET FROM MAIN
 CONTROLLER TO HOUSING

 4. INTERNAL MOTORS ARE ACCESSIBLE
 THROUGH HOUSING OPENING WHEN UNIT IS

DEPLOY	ED.		

REVISION							
REVISION NUMBER	REVISION DATE	REVISION DESCRIPTION					
D1	7.28.20	INITIAL RELEASE					

QUOTE: ---CONFIGURATION: PROJECT: ---DIST.: ----

.SIGN	SIZE		
DEL:	b		
ET TITLE 000 ELE	SHEET		
DRAWN:	TLM	7.28.2020	1 OF 1